

## Addendum No. 2

### 2010 Pump Station Rehabilitation – Hoge #2, Kings Row #1, Queen Way, Ridgeview #1 and Edmands Pump Stations PWP #WA-2010-109

The following information, clarifications, changes and modifications are by reference incorporated into the bid documents for the above referenced project. Any work item or contract provision not changed or modified will remain in full force and effect. The bid date and time and construction schedule remain the same.

- 1. Question:** Under which bid item should the new access lid cast-in-place on Sheet C4 be included?

**Response:** The new access hatch is being installed at the Ridgeview Drive Pump Station. The most appropriate Bid Item is number 26 as amended below:

**Question:** Does item 15, the Kings Row by-pass regulator vault need special interior coatings?

**Response:** No.

- 2. Technical Specifications:**

No changes in Addendum #2

- 3. Contract Drawings:**

Replace Sheets C2, C3, C6 with the attached drawings.

Add Sheet C7, note the total drawing count increases from 48 to 49.

- 4. Bid Schedule:**

Bid Schedule item #14:

**Scheduled Value:**

Delete: 862

Replace with: 1,820

#### 4. Cont.

Bid Schedule item #16:

**Scheduled Value:**

Delete: 85

Replace with: 160

**Replace the existing description with the new description provided below for Bid schedule item 16:**

16. Kings Row #1 6-inch restrained DIP, fittings and valves for by-regulator supply and discharge lines to from vault. Includes trenching/excavation & backfill, DIP pipe/fittings, poly-wrap, **2-12"x6"** hot-tap saddle/GTV.

(Note: added 2- before 12")

Bid Schedule item #23:

**Scheduled Value:**

Delete: 240

Replace with: 300

Bid Schedule item #26:

**Replace the existing description with the new description provided below:**

26. Ridgeview #1 Pump Station – Remove and salvage existing MH frames and covers, provide/install new MH frame and covers, grade rings, ~~and~~ concrete collars, **and replace existing access hatch.**

(Note: Added and replace existing access hatch)

#### 5. Miscellaneous

No miscellaneous items.