

Addendum No. 1

2009-2010 Flume Rehab – Lumber Purchase

Bid # 0910-115
September 17, 2009

The following information, clarifications, changes and modifications are by reference incorporated into the bid documents for the above referenced project. Any work item or contract provision not changed or modified will remain in full force and effect. The bid date and time and delivery schedule remain the same.

1.) The 8X8 is spelled out as being Douglas Fir, No. 1 btr, rough. None of the other lumber items state whether the lumber is surfaced 4 sides (S4S), or rough? If it is to be rough, is it standard sawn lumber or full sawn lumber; netting the full dimension if the lumber?

All lumber shall be S4S except when noted to be rough sawn. Rough sawn lumber shall be standard sawn (approximately 1/8" larger than dressed lumber).

2.) Are heart centers allowed in the 6X6 and 8X8 or is it to be free of heart center (FOHC)? Heart centers in lumber often will twist as it dries.

FOHC lumber is not required.

3.) Does the lumber need to be dried to 19% before or after treatment?

Lumber shall be at 19 percent moisture content at time of surfacing.

End of Addendum No. 1