

Addendum No. 1

Valley Road Main Replacement

Bid # 0910-87
TMWA Project No. 04-121
August 24, 2009

The following information, clarifications, changes and modifications are by reference incorporated into the bid documents for the above referenced project. Any work item or contract provision not changed or modified will remain in full force and effect. The bid date and time and construction schedule remain the same.

1. Delete the Bid Schedule originally provided in the bid document and replace with the new Bid Schedule provided with this addendum. If you have already completed pages **beyond the pricing schedule** you can use those already completed pages for submission and will not be required to complete them again. The new pricing schedule has 68 numbered lines.
2. The Contractor will not be granted extra compensation for evening or weekend work necessary to minimize service outages for the Sierra Vista School or University of Nevada associated housing. The Contractor will be required to adjust his work schedule to minimize these outages and should make appropriate provisions..
3. A copy of the Consent Letter, from UPRR, is attached. UPRR is not the underlying fee holder for this crossing. As such, Railroad Protection Insurance is voluntary and not mandatory. The Contractor shall coordinate with, and notify, UPRR staff as called for in the Consent Letter. Prospective Bidders are strongly encouraged to visit <http://www.up.com> for insurance costs and requirements.
4. The following changes are made to Drawing P1, Sta 2+00 to 7+50:
 - a. Sta 4+35.1: The requirement for a blow-off assembly at this location is deleted.
5. The following changes are made to Drawing P3, Sta 3+00 to 18+50:
 - a. Sta 18+00: The linework on the Drawings indicates a connection to a 6-inch water line in Manogue Road. This connection will not be required and there is no associated Detail for this connection.
6. The following additions are made to Drawing P6:
 - a. In the vicinity of Sta 31+75 a connection to an existing 8-inch fire service for 2400 Valley Road shall be made. The connection shall be made in a layout similar to that shown on Detail 2 of Sheet D2 of the Drawings. Materials shall include: One 12"x8" MJxFLG Tee, One 8" FLGxMJ resilient wedge gate valve, two 8" MJ 90 deg elbows, two 8" MJ 45 deg elbows, one 8" closure coupling, 24 ft. of 8" poly-wrapped DIP, two 12" megalugs and nine 8" megalugs. A 1" Water Service Connection (WSC) shall also be made in this vicinity to serve 2400 Valley Road.
7. The following additions are made to Drawing P-6:
 - a. In the vicinity of the intersection of Valley Road and Enterprise Road a 2-inch temporary flush assembly shall be furnished and installed on the 14" transite main heading south along Valley Road. Removal/retirement of the flush assembly shall be required.

8. The following changes are made to Drawing D1, Connection Details:
 - a. Detail 1: The callout for the 14x12 tapping sleeve shall include a requirement for the tapping nozzle to have a minimum inside diameter so as to allow for the requirement of an 11-7/8 inch cutter to complete the tap.
9. The following clarification is made to Drawing D1, Connection Details:
 - a. Detail 5: The price for the 12-inch main and fittings (shown in this Detail) is to be included in Item 8 of the Bid Proposal. The intent of the Detail is to show specific detailing for the connections and not for the main.
10. The following changes are made to Drawing D4, Connection Details:
 - a. Detail 1: The detail is oriented incorrectly with respect to what is shown at Sta 17+79.0 of Sheet P3. However, the fittings required to make the connection are indicated properly with the exception of the final 6" 90 deg MJ elbow installed prior to making the connection to the existing 6-inch line. This elbow shall be replaced with a 6" 45 deg MJ elbow.
11. The following changes are made to Drawing D4, Connection Details:
 - a. Detail 4: The requirement for the 14x12 JCM 414 shall be deleted and changed to a 14x12 JCM 432. The 14x12 tapping sleeve shall include a requirement for the tapping nozzle to have a minimum inside diameter so as to allow for the requirement of an 11-7/8 inch cutter to complete the tap.

Attachments:

Bid Schedule

Union Pacific Consent Letter

End of Addendum No. 1