

REPS

23792 Yosemite Blvd., Waterford, CA 95386

(209) 874-3640

Date: June 19, 2008**Service - PM Report**Customer : Truckee MeadowsContact : Will RaymondLocation : GlendalePhone # 775-834-8138

Product Supplier : _____

Supplier Customer # _____

Product : Co2 Nitrogen Oxygen Argon Nitrous Oxide Hydrogen Other **Storage Vessel :**Manufacturer : Tomco Storage Capacity 30 Ton Yr. Bld. 2005Model # _____ Serial # 05282 N.B. # 9329**Condensing Unit :**Manufacturer : Copeland Model # 2DF3-030E-TFD-100Refrigerant : 404A Expansion Valve : SQL5 Expansion Valve Model # _____Power Head Assy. GQE-5(2T)SZP Voltage : 480 Ph 3 Amperage : 76.8 - 73**#1 - Description** PB VAPORIZERManufacturer : TOMCO Capacity : _____Model # 300-XCF-18-480-46SS-LT3 Serial # B-922NKW 18 Voltage : 480 Ph 3 Amperage : 21.3 - 21.7**#2 - Description** VAPOR HEATERManufacturer : TOMCO Capacity : 4000#/HRModel # FS-CVH 4 Serial # 2155KW 4 Voltage : 480 Ph 1 Amperage : 6.9 - 7.1**#3 - Description** _____

Manufacturer : _____ Capacity : _____

Model # _____ Serial # _____

KW _____ Voltage : _____ Ph _____ Amperage : _____

#4 - Description _____

Manufacturer : _____ Capacity : _____

Model # _____ Serial # _____

KW _____ Voltage : _____ Ph _____ Amperage : _____

#5 - Description _____

Manufacturer : _____ Capacity : _____

Model # _____ Serial # _____

KW _____ Voltage : _____ Ph _____ Amperage : _____

