

# **Addendum No. 1**

## **2010/2011 Tank Improvements**

### **TMWA Project #05-001**

#### **Bid # 1011-200**

#### **February 11, 2011**

The following information, clarifications, changes and modifications are by reference incorporated into the bid documents for the above referenced project. Any work item or contract provision not changed or modified will remain in full force and effect. The bid date and time remain the same.

#### **Bid Document:**

The Scope of Work has been revised to include placement, grading, and rolling of 4" of Type 2 Class B aggregate base over the abandoned Mogul #1 Tank site, the Mogul #2 tank perimeter road, and the tank access road as shown on Figure 01. Figure 01 is attached to this Addendum by reference. Approximate material required is 160 cubic yards based on an area of 12,900 square feet. This change includes a corresponding deletion of the road base component from Bid Item 2.

The Engineer's estimate has been updated to \$271,500 - \$331,800 to reflect this additional work. This change will be reflected in the conformed bid document on the invitation to bid.

Two additional days have been added to the contract time making the revised completion date April 18, 2011. This change will be reflected in the conformed bid document on the invitation to bid and the sample contract.

Remove page BS-2 from the Bid Schedule and replace with the revised page BS-2 following this page of the Addendum and labeled Addendum No. 1 in the footer.

Attachments: Figure 01 Posted to the website as a separate attachment below this Addendum.

End of Addendum No. 1

# BID SCHEDULE

June 21, 2010

**NOTICE:** No substitution or revision to this Bid Schedule form will be accepted. Truckee Meadows Water Authority will reject any Bid that is received that has changes or alterations to this document. Although the Prevailing Wages are provided in this bid document, the bidder is responsible to verify with the Labor Commissioner if any addendums have been issued. If different, the successful bidder will be required to provide the current Prevailing Wages used in preparation of their bid within 24 hours of bid submission.

**BID #** 1011-200

**BID TITLE:** 2010/2011 Tank Improvements

**PRICES** must be valid for 30 calendar days after the bid opening.

**A COPY OF THE "CERTIFICATE"** of eligibility to receive a preference in bidding on public works issued to him/her by the State Contractors' Board must be submitted with his/her bid to the Contracts Division in accordance with N.R.S. 338.147 for the preference to be considered. This Statute does not apply to projects expected to cost less than \$250,000.

**COMPLETION** of this project is expected **PURSUANT TO CONTRACT DOCUMENTS**.

**BIDDER** acknowledges receipt of \_\_\_\_\_ Addendums.

\_\_\_\_\_  
(signature)

**SUMMARY**

Description	Scheduled Value	Unit	Unit Price	Total Price
1. Mobilization, insurance, bonds, submittals, and misc. permits as required.	1	LS		
2. Demolish existing 0.22 million gallon Mogul #1 bolted steel tank and dispose of properly. Includes utility abandonments, and final grading.	1	LS		
3. Modifications to the 0.42 million gallon Mogul #2 welded steel tank. Includes both TMWA- and Contractor-provided appurtenances.	1	LS		
4. Interior and exterior coating of finished Mogul #2 steel tank including washdown.	1	LS		
5. Placement, grading and compaction of Type 2 Class B aggregate base at the Mogul Tank site				
6. Interior coating of the 1.5 million gallon Skyline #1 steel tank including washdown.	1	LS		
7. Demobilization and cleanup.	1	LS		
<b>7.TOTAL BID PRICE (Items 1 – 6)</b>				

**8.Total Bid Price Written in Words:**