



# **Addendum No. 1**

## **Glendale Water Treatment Facility Generator Additions**

TMWA Bid No.: 2018-001

TMWA Capital Project No.: 11-0013

August 15, 2017

The following information, clarifications, changes and modifications are by reference incorporated into the bid documents for the above referenced project. Any work item or contract provision not changed or modified will remain in full force and effect. The bid date and time and construction schedule remain the same.

### **QUESTIONS AND RESPONSES**

**Question No. 1:** I received the RFP for the project and wondered if there was a fuel system for the generators, or if they are coming with belly tanks. If you could please let me know I would greatly appreciate it.

**Response to Question No. 1:** The diesel fuel tanks and fuel delivery systems are included with and integrated as part of both generators being supplied by Truckee Meadows Water Authority.

**QUESTION CUTOFF DATE: SEPTEMBER 8, 2017**

**End of Addendum No. 1**