
1355 Capital Blvd. • P.O. Box 30013 • Reno, NV 89520-3013
P 775.834.8080 • F 775.834.8003

Addendum No. 2

Chalk Bluff Solids Handling and Disposal

TMWA Project No.: 2015-002
September 25, 2014

The following information, clarifications, changes and modifications are by reference incorporated into the bid documents for the above referenced project. Any work item or contract provision not changed or modified will remain in full force and effect. The bid date and time and construction schedule remain the same.

QUESTIONS AND RESPONSES

Question No. 1: Is the dredge that is currently in the Raw water basin #1 something that could be made available to the successful contractor?

Response to Question No. 1: The dredge is not available for use in the removal of solids. However, the associated piping used to move solids and water to the solids storage basin is available to the contractor. If the contractor elects to use the solids piping, raw water will need to be used to flush the line to the satisfaction of the project representative.

Question No. 2: Is there water available from the onsite hydrants to aid in cleanup?

Response to Question No. 2: The onsite hydrants will be made available for use during this project with the approval of the project representative. All equipment receiving water onsite will need to be equipped with an approved backflow device (air gap preferred).