

1355 Capital Blvd. • P.O. Box 30013 • Reno, NV 89520-3013  
P 775.834.8080 • F 775.834.8003

**Addendum No. 3**  
**OLD WASHOE 4 WELL**  
PWP No.: WA-2016-064  
TMWA Project No.: 15-0031

January 25, 2016

The following information, clarifications, changes and modifications are by reference incorporated into the bid documents for the above referenced project. Any work item or contract provision not changed or modified will remain in full force and effect. The bid date and time and construction schedule remain the same.

**Questions, Responses, and Clarifications**

- A. Question No. 1:** Section 43 40 01 (Polyethylene Storage Tank), Part 1, 1.04 A.1.c. under shop drawings calls for a Nevada registered Engineer to sign shop drawings and calculations regarding the hypochlorite storage tank. The specified manufacturer, Chem-Tainer, has quoted us on the tank and associated accessories per the spec, however, they do not offer the required Engineer's approval. An equal tank brand is allowed, but it is likely that the requirement won't be met since these tanks are manufactured elsewhere and will only be constructed per their specs. We were told by Chem-Tainer that their specifications are primarily on the website. We are curious to know if the spec regarding the Nevada Engineer's approval is going to be enforced, considering this situation.

**Response to Question No. 1:** No, this requirement will not be enforced. Reference Technical Specifications revision included as part of this addendum below.

**B. Technical Specifications:**

1. Section 43 40 01 Polyethylene Storage Tank, Part 1.04 A. 1. c, DELETE the following paragraph in its entirety:
  - c. Tank Shop Drawings and associated calculations shall be sealed and signed by a licensed civil or structural Engineer currently registered in the state of Nevada.

**END OF ADDENDUM #3**