
1355 Capital Blvd. • P.O. Box 30013 • Reno, NV 89520-3013
P 775.834.8080 • F 775.834.8003

Addendum No. 2

2015 Pressure Regulator Station Rehabilitation

TMWA Capital Project Number 16-0008
September 21, 2015

The following information, clarifications, changes and modifications are by reference incorporated into the bid documents for the above referenced project. Any work item or contract provision not changed or modified will remain in full force and effect. The bid date and time and construction schedule remain the same.

Questions and Responses:

Questions/Clarifications:

Question No. 1: Is the type of existing pipe inside the Belford #1 station known? Is there a preferred method to install the new 2" outlet inside this station (weld o-let or service saddle)?

Response to Question No. 1: The pipe is 6-inch schedule 40 steel, the new 2" outlet shall be installed with a thred-o-let per detail 2/D1.

END OF ADDENDUM 2