

1355 Capital Blvd. • P.O. Box 30013 • Reno, NV 89520-3013
P 775.834.8080 • F 775.834.8003

Addendum No. 2
OLD WASHOE 4 WELL
PWP No.: WA-2016-064
TMWA Project No.: 15-0031

January 20, 2016

The following information, clarifications, changes and modifications are by reference incorporated into the bid documents for the above referenced project. Any work item or contract provision not changed or modified will remain in full force and effect. The bid date and time has been extended; however, the construction schedule remains the same.

CLARIFICATION ITEMS

A. Technical Specifications:

1. Section 26 05 01 Electrical, Part 2.23 B. 3, REPLACE entire paragraph with the following:
 3. Submersible Pump Power Cable: Cable shall be 600-volt and 75 degrees C rated Type THW UL-listed submersible pump cable that is RoHS compliant. Cable shall consist of three No. 1 AWG power and one No. 6 AWG ground conductors individually insulated; cable assembly shall be covered with a flat heavy duty PVC outer jacket. Splices will not be allowed in the cable, except at connection to motor cables and at junction box above ground surface. Cable supplied shall be approximately 360 feet long, of adequate length to run from motor cable splice to 6 feet above ground surface.
 - a. Manufacturers:
 - 1) Paige Electric.
 - 2) Service Wire Company.
 - 3) Or equal.
2. Section 40 27 01 Process Piping Specialties, Part 2.06 E, REPLACE entire paragraph with the following:
 - E. Manufacturers and Products:
 1. Baker Water Systems Division; Monitor Industrial Pitless Unit.
 2. Or equal.

The bid opening for this project has been extended. All sealed bids must be received by TMWA no later than 11:00 a.m. on January 28, 2016. Bids received after the date and time set for receipt will be rejected.

QUESTION CUT-OFF DATE IS JANUARY 22, 2016 AT 11:00 A.M.

Page 1 of 1