

1355 Capital Blvd. • P.O. Box 30013 • Reno, NV 89520-3013
P 775.834.8080 • F 775.834.8003

Addendum No. 1

PRODUCTION WELL REHABILITATION FOR 2016-2017

PWP Bid No. WA-2017-027

November 15, 2016

The following information, clarifications, changes and modifications are by reference incorporated into the bid documents for the above referenced project. Any work item or contract provision not changed or modified will remain in full force and effect. The bid date and time and construction schedule remain the same.

**CLARIFICATION AND CHANGES TO BID SCHEDULE,
DELETIONS TO TECHNICAL SPECIFICATIONS
AND
QUESTION AND RESPONSE**

CLARIFICATION AND CHANGES TO BID SCHEDULE

1. STMGID 1 WELL REHAB – Zolezzi Lane, Reno, NV 89511

Bid Schedule Changes:

- Please change bid item No. 22 and delete 900 and replace with 90 degree elbows
- STMGID 1, page 5: Delete Line Item 20, the chlorine disinfection step (*see response to Question No. 1 listed below*)

2. MT. ROSE 6 WELL REHAB PROJECT – 6185 Lake Geneva Drive, Reno, NV 89520

- Please change bid item no. 21 and delete 900 and replace with 90 degree elbows
- Mt. Rose 6, page 8: Delete Line Item 19, the chlorine disinfection step (*see response to Question No. 1 listed below*)

3. MT ROSE 3 WELL REHAB PROJECT – Millie Lane, Reno, NV 89511

- Please change bid item no. 21 and delete 900 and replace with 90 degree elbows
- Mt. Rose 3, pager 10: Delete Line Item 19, the chlorine disinfection step (see response to Question No. 1 listed below)

4. STMGID 2 WELL RHAB PROJECT – Silver Wolf Road, Reno, NV 89511

- Please change bid item no. 21 and delete 900 and replace with 90 degree elbows
- STMGID 2, page 12: Delete Line Item 19, the chlorine disinfection step (see response to Question No. 1 listed below)

DELETIONS TO THE TECHNICAL SPECIFICATIONS:

- 1. STMGID 1:** Delete items 18 and 19, the chlorine disinfection steps (see response to Question No. 1 below)
- 2. Mt. Rose 6:** Delete items 17 and 18, the chlorine disinfection steps (see response to Question No. 1 below)
- 3. Mt. Rose 3:** Delete items 17 and 18, the chlorine disinfection steps (see response to Question No. 1 below)
- 4. STMGID 2:** Delete items 17 and 18, the chlorine disinfection steps (see response to Question No. 1 below)

QUESTION AND RESPONSE:

Question No. 1: Line item 18 or 19 for all 4 wells states: Purge and neutralize the well using sodium thiosulfate before discharging to an approved storm drain.

Could I please have some parameters on how to purge the well? I assume this will be pumped and if so what depth are we installing the pump and at what GPM will we be pumping?

Response to Question No. 1: The steps to disinfect, purge, and neutralize (with sodium thiosulfate) the chlorine mix will **not** be performed by the contractor. Please refer to the two, above-referenced sections which include clarification and changes to the Bid Schedule and deletions to the Technical Specifications.