



NOTES:

1. ASSEMBLY SHALL BE A USC APPROVED DEVICE.
2. THE ENTIRE MANIFOLD SHALL BE EXPOSED WITHIN THE ABOVE GROUND BOX OR BELOW GROUND VAULT.
3. REFER TO THE RP OR DC STANDARD FOR INSTALLATION DETAILS.
4. SUPPORTS SHALL BE PROVIDED AS NECESSARY.
5. FOR VAULT INSTALLATION REFER TO 10A-5 FOR DEPTH, PIPING, LADDER, VAULT AND PENETRATION REQUIREMENTS.
6. NO STOP AND WASTE VALVES.
7. CALL LOCAL BUILDING AND/OR FIRE DEPARTMENTS FOR DEPTH AND TYPE OF PIPE TO BE USED.
8. INSPECTION BY TMWA BACKFLOW PREVENTION GROUP PERSONNEL REQUIRED BEFORE METER IS SET OR SERVICE IS ACTIVATED.
9. TESTING OF BACKFLOW ASSEMBLY REQUIRED WITHIN 7 DAYS AFTER METER IS SET OR SERVICE ACTIVATION. COPY OF TEST RESULTS TO BE FORWARDED TO TMWA BACKFLOW PREVENTION GROUP PERSONNEL BY A CERTIFIED ASSEMBLY TESTER WITHIN THAT SAME TIMEFRAME.
10. THRUST BLOCKS ARE REQUIRED AT ALL BELOW GRADE ELBOWS (TO BE SIZED BY ENGINEER).



DATE

7/2001

REV

7/2011

APPENDIX 10A
 BACKFLOW PREVENTION ASSEMBLIES
 FIRE-CLASS 1 TO 6 CONTINUOUS FLOW SERVICES
 MANIFOLD FOR PARALLEL BACKFLOW
 ASSEMBLIES

DRAWING NUMBER

10A-12