



NOTES:

1. REFERENCE NAC 445A, TMWA CONSTRUCTION AND DESIGN STANDARDS AND JURISDICTIONAL FIRE AGENCY FOR REQUIRED PIPE MATERIALS. POLYETHYLENE WRAP TO BE USED ON ALL DUCTILE IRON PIPE AND FITTINGS PER AWWA C105.
2. REFER TO PLAN FOR ACTUAL DIAMETER AND LENGTH FOR HYDRANT LATERAL.
3. KEEP A MINIMUM OF 2" CLEARANCE BETWEEN FLANGES/BOLTS AND CONCRETE.
4. LOCATION OF FIRE HYDRANT TO BE DETERMINED BY APPROPRIATE GOVERNMENTAL FIRE AGENCY. FIRE HYDRANT AND BARREL EXTENSION TO BE SUPPLIED BY OTHERS.
5. REFER TO JURISDICTIONAL AGENCY'S ADOPTED FIRE CODE FOR HYDRANT TYPE, COLOR AND CONNECTION TYPES.
6. ALL EXPOSED METAL MUST BE COATED AND WRAPPED.
7. REFER TO CITY STANDARDS OR APPENDIX 10L FOR THRUST BLOCK REQUIREMENTS. USE THE MOST CONSERVATIVE.



DATE

7/2001

REV

9/2016

APPENDIX 10F
FIRE PROTECTION INSTALLATIONS

6" FIRE HYDRANT SERVICE
OFF NEW MAINS

DRAWING NUMBER

10F-2