



NOTES:

1. REFERENCE NAC 445A, TMWA CONSTRUCTION AND DESIGN STANDARDS AND JURISDICTIONAL FIRE AGENCY FOR REQUIRED PIPE MATERIALS. POLYETHYLENE WRAP TO BE USED ON ALL DUCTILE IRON PIPE AND FITTINGS PER AWWA C105.
2. REFER TO PLAN FOR ACTUAL DIAMETER AND LENGTH FOR FIRE SERVICE LATERAL.
3. KEEP A MINIMUM OF 2" CLEARANCE BETWEEN FLANGES/BOLTS AND CONCRETE.
4. ALL EXPOSED METAL MUST BE COATED AND WRAPPED.
5. REFER TO CITY STANDARDS OR APPENDIX 10L FOR THRUST BLOCK REQUIREMENTS. USE THE MOST CONSERVATIVE.
4. REFER TO APPROVED PLAN AND APPENDIX 10A FOR APPROPRIATE BACKFLOW DEVICE.



DATE

7/2001

REV

9/2016

APPENDIX 10F
FIRE PROTECTION INSTALLATIONS

FIRE SERVICE
OFF NEW MAIN

DRAWING NUMBER

10F-3