



NOTES:

1. ALL TRENCHES MUST CONFORM TO APPLICABLE TMWA, CITY, STATE, COUNTY, AND OSHA SPECIFICATIONS AND REQUIREMENTS. IN THE CASE OF CONFLICT, THE MORE RIGID SPECIFICATION OR STANDARD SHALL APPLY.
2. BEDDING SAND SHALL BE COMPACTED TO 90% MAXIMUM DENSITY PER SECTION 5.05.03 AND SHALL BE A MINIMUM OF 12" ABOVE AND 6" BELOW THE MAIN. PER SECTION 5 OF TMWA STANDARDS.
3. CRUSHED AGGREGATE BASE COURSE BACKFILL SHALL BE PLACED IN 12" MAXIMUM LOOSE LIFTS. THE TOP 12" SHALL BE COMPACTED TO 95% MAXIMUM DENSITY. THE AREA ABOVE THE BEDDING SAND & BELOW 12" FROM FINISH GRADE SHALL BE COMPACTED TO 90% MAXIMUM DENSITY. PER SECTION 5 OF TMWA STANDARDS.
4. METALLIC WATER AND GAS LOCATOR TAPE SHALL BE PLACED IN ALL TRENCHES AT LEAST 12" ABOVE THE GAS.
5. ELECTRIC UTILITIES MUST BE LOCATED BELOW WATER & MAINTAIN 2' MINIMUM RADIAL CLEARANCE FROM TMWA WATER FACILITIES. IF 2' RADIAL CLEARANCE CAN NOT BE MET ELECTRIC CONDUIT MUST BE CONCRETE ENCASED AT LEAST 18" EACH SIDE OF WATER CROSSING. FIBER OPTIC AND/OR COMMUNICATION CONDUITS SHALL NOT BE PLACED IN THE SAME TRENCH AS WATER.
6. ALL CHANGES MUST BE APPROVED BY THE TMWA INSPECTOR AND/OR THE TMWA ENGINEER.
7. SEPARATION FOR PIPES IN A JOINT TRENCH SHALL BE A MINIMUM OF 12".



DATE

7/2011

REV

02/2014

APPENDIX 10L
MISCELLANEOUS WATER DETAILS

TRENCH DETAIL
GAS AND WATER

DRAWING NUMBER

10L-7