



1. COUPLINGS SHALL BE ROMAC STYLE 501, FUSION EPOXY COATING, CENTER RING LENGTH MINIMUM 7".
2. BACKFILL AND COMPACTION REQUIREMENTS SHALL COMPLY WITH SECTION 5, TRENCH BEDDING, BACKFILL & EXCAVATION.
3. REPLACEMENT SECTION OF PIPE SHALL BE DUCTILE IRON.
4. REFER TO TMWA CONSTRUCTION AND DESIGN STANDARDS FOR MINIMUM CLEARANCE REQUIREMENTS.



DATE
7/2011
REV

APPENDIX 10L  
 MISCELLANEOUS WATER DETAILS  
 CROSSING UNDER EXISTING TRANSITE OR  
 SMALL DIAMETER CAST IRON MAINS

DRAWING NUMBER

10L-8