
1355 Capital Blvd. • P.O. Box 30013 • Reno, NV 89520-3013
P 775.834.8080 • F 775.834.8003

Addendum No. 1

2016-2017 Tank Improvements

TMWA Bid No. 2017-055
January 10, 2017

The following information, clarifications, changes and modifications are by reference incorporated into the bid documents for the above referenced project. Any work item or contract provision not changed or modified will remain in full force and effect. The bid date and time and construction schedule remain the same.

Clarification, Questions and Responses

Question No. 1: Please clarify thickness of floor plate, 5/16" as shown on Sheet C102 Detail 3/C102 or 1/4" as shown on Sheet C103 Detail 2/C103.

Response to Question No. 1: Plate thickness for the new floor shall be 5/16"

END OF ADDENDUM 1