



Addendum No. 2
Chalk Bluff Water Treatment Plant Backup Power Generator
PWP Bid No.: WA-2019-039
TMWA Capital Project No.: 13-0023
January 3, 2019

The following information, clarifications, changes and modifications are by reference incorporated into the bid documents for the above referenced project. Any work item or contract provision not changed or modified will remain in full force and effect. The bid date and time and construction schedule remain the same.

Questions, Responses, and Modifications

A. Question No. 1:

In reviewing the plans and specs I don't see a conduit and cable schedule for the wiring that will be needed to bid this job, it appears the conduit and wiring to the new generator for the power conductors is not shown. Please confirm if the engineer will be providing this, thank you.

Response to Question No. 1:

Conduit and conductor information is depicted on Drawing E-13.

B. Technical Specifications:

1. REVISE Part 2.07 A. of Technical Specification 26 32 13 Diesel Medium-Voltage Generator Set as follows:
 - A. The generator set supplier is responsible for providing a properly sized cooling system. The cooling system shall be sized to maintain safe operation at 50 degrees C (**122 degrees F**) maximum ambient temperature at 5,000 feet above sea level. Total cooling water demanded by system shall not exceed 200 gpm at an anticipated temperature of ~~65~~ **103** degrees F.

End of Addendum No. 2