

1355 Capital Blvd. • P.O. Box 30013 • Reno, NV 89520-3013
P 775.834.8080 • F 775.834.8003

Truckee Meadows Water Authority Guidelines for Estimating Maximum Day Demands EFFECTIVE OCTOBER 1, 2019

Single-Family Residential Unit:

$$Y = 0.0066 * \sqrt{x}$$

Y = maximum day demand in gpm, demand capped at 1.5 gpm per lot
x = lot size in square feet

Add irrigation for common areas as needed

Domestic Multi-Family Units:

$$Y = 0.14 \text{ gpm per unit}$$

Y = maximum day demand in gpm

Add irrigation for common areas as needed

Commercial/Industrial:

$$Y = \text{water rights demand (in acre-feet)} * 1.08$$

Y = maximum day demand in gpm

Add irrigation for common areas as needed

Potable Irrigation:

$$Y = \text{water rights demand (in acre-feet)} * 1.73$$

Y = maximum day demand in gpm

NOTES:

1. These guidelines are meant for estimating purposes only. The Truckee Meadows Water Authority will determine actual project demands after a complete application for service is received.
2. These guidelines are subject to change by the Truckee Meadows Water Authority at any time.