

Quality. Delivered.

Addendum No. 1 Precast Concrete Vaults and Catch Basins for the Arrowcreek Drought Response Project TMWA Project No. 2016-002 August 4th, 2015

The following information, clarifications, changes and modifications are by reference incorporated into the bid documents for the above referenced project. Any work item or contract provision not changed or modified will remain in full force and effect. The bid date and time and construction schedule remain the same.

QUESTIONS AND RESPONSES

Having reviewed the plans and specs for the subject project, I request clarification on the following items:

Question No. 1: In the specifications 03480 2.2 Utility vaults states.."all vaults shall be closed bottom", however the mechanical details show the majority of these vaults to have either open sumps (2' x^2 w/ grate) and sloped to the sump, or 2' x 2' x1' deep closed sump w/grate. Details indicate that these are to be saw cut. Due to the wording in the specs, is it to be assumed that these vaults be manufactured and supplied with closed bottoms and the sumps will be installed in the field by the contractor ?

Response to Question No. 1: Correct. The manufacturer vaults will be closed bottom and the sumps will be cored or poured by the Contractor.

Question No. 2: Hatches : In section "D" (1): Saf-T-"Grate type grating style fall protection shall be provided on all access hatches unless shown otherwise)". The vault descriptions per 03480-1 designate the requisite hatches for the various vaults, however Fall Protection is only called out for the 6' x 6' x 10'-6" surge tank vaults. Does this mean that these are the only two hatches need fall protection?

Response to Question No. 2: Delete Saf-T –Grates from the specification. These will not be required and the grates for the Surge Tank Vaults will be fabricated and installed by the Contractor.

Question No. 3: Vault dimensions: Are the heights of these vaults as called out measured from the inside floor to top of wall, or from the outside of the inside floor to the top of wall? (the dimensions shown for the 6×8 vault show the outside vertical dimension of our standard 687 vault). Please clarify.

Response to Question No. 3: Dimensions for the design are based on Jensen Standard Cut-Sheets, please see attached.


Question No. 4: At the end of the bid item summary, it asks if a crane will be needed; This question is difficult to answer with a "yes" or "no" answer; Depending upon your answers to question 1, the $6 \times 8 \times 7$ '-8" vaults will probably need to be set with a crane, however most of the others can probably be set with a boom truck depending upon access and site conditions.

Response to Question No. 4: Please let us know if the answer to Question 1 gives you enough information to answer the crane question.

Question No. 5: In your Specifications 03480-5 Under Ladder Options Paragraph 1a (Internal Ladders) the specification states: "For Ladders less than 15' depth, install a Head Hazard Deflector Plate" (Please see attached document).


We are not familiar with that item. Could you please provide a detail for such? Where can these be obtained.

Response to Question No. 5: Deflector Plates are metal or plastic plates placed on protruding potential hazards within 30 inches of the centerline of the rungs or cleats. The plates are to be installed at an angle of 60 degrees from the horizontal as indicated in figure D-5 attached.



MODEL	A	В	INSIDE V	OLUME	APPROX. WT.
6060U-48	4'-0"	4'-6"	100 CU. FT.	748 GAL.	9300 LBS.
6060U-60	5'-0"	5'-6"	125 CU. FT.	935 GAL.	10950 LBS.
6060U-72	6'-0"	6'-6"	150 CU. FT.	1110 GAL.	12600 LBS.






MODEL	Α	В	INSIDE V	OLUME	APPROX. WT.
66-6-U	7'-3"	5'-11"	217 CU. FT.	1623 GAL.	28600 LBS.
66-7-U	8'-3"	6'-11"	255 CU. FT.	1907 GAL.	31300 LBS.
66-8-U	9'-3"	7'-11"	293 CU. FT.	2191 GAL.	34100 LBS.

FOR COMPLETE DESIGN AND PRODUCT INFORMATION CONTACT JENSEN PRECAST. SEE ACCESSORIES SECTION FOR ACCESS OPENINGS AND HARDWARE APPLICATIONS.



1/17/03 66Ux8''wall.dwg © 2003 Jensen Precast



MODEL	Α	В	INSIDE V	OLUME	APPROX. WT.
68-6-U	7'–3"	5'-11"	288 CU. FT.	2154 GAL.	25413 LBS.
68-7-U	8'-3"	6'-11"	336 CU. FT.	2513 GAL.	28500 LBS.
68-8-U	9'—3"	7'-11"	384 CU. FT.	2872 GAL.	31587 LBS.


FOR COMPLETE DESIGN AND PRODUCT INFORMATION CONTACT JENSEN PRECAST. SEE ACCESSORIES SECTION FOR ACCESS OPENINGS AND HARDWARE APPLICATIONS.



1/17/03 68Ux8''wall.dwg © 2003 Jensen Precast

MODEL 4848-U

48" INSIDE X 48" INSIDE LENGTH



SEE ACCESSORIES SECTION FOR ACCESS OPENINGS AND HARDWARE APPLICATIONS.

MODEL	Α	В	INSIDE V	OLUME	APPROX. WT.
4848U-48	4'-0"	4'-6"	64 CU. FT.	474 GAL.	3900 LBS.
4848U-60	5'-0"	5'-6"	80 CU. FT.	592 GAL.	8625 LBS.
4848U-72	6'-0"	6'-6"	96 CU. FT.	710 GAL.	9975 LBS.




1/17/03 48x48_U.dwg © 2003 Jensen Precast

FRAME AND GRATE						
MODEL NO.	RATING	Е	WEIGHT			
FG4848P	PEDESTRIAN	1 1/2"	242 LBS.			
FG4848I	TRAFFIC	5"	1000 LBS.			

48"x48" DROP INLET

UP TO 6'-0" INSIDE DEPTH




AND PRODUCT INFORMATION, CONTACT JENSEN PRECAST.

8/31/00 DI4848.dwg © 2000 Jensen Precast

BOX





PRECAST ®


10/11/00


1616 D.I. BOX

2'-2"

40

6"





2/2/04 DI3636CF.dwg © 1997 Jensen Precast






FIGURE D-5.-Deflector Plates for Head Hazards